



italtec

Company with Quality
System Certified by DNV
ISO 9001/2000

SAFETY EQUIPMENT PHASE SEQUENCE INDICATOR

PHASE SEQUENCE INDICATOR

Mod. SL

For the exact phase sequence control (L1, L2, L3 or L2, L1, L3) or the missing phase (both lamp lighted)

- Test voltage 4kV
- Operating voltage: 100-400V



SEQ-200/400V PHASE SEQUENCE INDICATOR

Hand-held instrument for the check of the phase sequence in a three-phase system with industrial frequency.
Working voltage: 200-400V.

Copyright © italtec s.r.l. All Rights Reserved

Ci riserviamo di apportare modifiche e migliorie senza preavviso
We reserve the right to change these specifications without notice
Photos et données techniques susceptibles de modifications sans avis

ITALTEC S.R.L. SISTEMI TECNICI DIDATTICI
20090 FIZZONASCO MI (Italy) – Via privata Liguria, 3
Tel. +39 02-90.721.606 Fax. +39-02-90.720.227
e-mail: italtec@italtec.it <http://www.italtec.it>